



July 7, 2006

22 LAWRENCE AVE. • SUITE 308
SMITHTOWN, N.Y. 11787
TEL: 631-360-0006
FAX: 631-360-0277
WWW.ECGSERVICES.COM

Mr. Robert Cozzetto
Health and Safety Director
Lindenhurst UFSD
887 Kellum Street
Lindenhurst, NY 11757

**Re: Albany Avenue Elementary School
IAQ – Rooms 114A and 114B
ECG Project No. 2191**

Dear Mr. Cozzetto:

In accordance with your request, I visited the above referenced classrooms in response to occupant complaints of a possible Indoor Air Quality problem. Prior to my visit, I reviewed previous reports of mold and bacteria testing conducted by Olmsted Environmental Services, Inc. and CTI Environmental Consultants. In addition, I was provided with copies of "Air Quality Assessment Questionnaires" completed by the occupants Ms. Eileen Biggs (Room 114A) and Ms. Maria Bohres (Room 114B).

The building inspection identified two rooms created from one existing classroom. Room 114A did not contain a univent or other source of fresh air except for operable windows which are not usable during cold winter months. Window leaks existed previously, but repairs were made and wet ceiling tiles were removed. The rooms were also recently cleaned with a disinfectant. The rooms contained excessive storage of stuffed animals, paper, books, toys, live plants, etc.

Room 114B contained a univent, a bathroom, and a sink. Ceiling tiles had been wet recently due to window leaks and were replaced. Both rooms had dust on the blinds, univents, and throughout the room.

An interview with the teachers revealed the following:

- In room 114A Ms. Biggs complained of coughing, stuffiness, headaches, tiredness, a mold-like smell, and skin rashes on her face.
- In room 114B Ms. Bohres complained of headaches, shortness of breath, swelling of face and eyes, dry eyes, and skin rash.